

GLOBAL SOLUTIONS IN ENGINEERING

Buildings



Municipal Infrastructure



Transportation



Industrial



Energy



Environment



NorthWestern Energy Wind Integration Study

Lessons Learned and Other Opportunities

Utility Variable-Generation Integration Group
Operating Impacts and Integration Studies Users Group Meeting

Tuesday, October 23, 2012

Andre Shoucri, P.Eng.

Buildings



Municipal Infrastructure



Transportation



Industrial



Energy



Environment



GENIVAR

Presentation Overview


- Project Background
- GENIVAR's Integration Study Approach
- Scope of NWE Wind Integration Study
- Scenario Descriptions
- Dispatch Simulation Overview
- Dispatch Simulation Results
- Lessons Learned
- Other Possibilities

Project Background

- 2004 - 2005: Participated in AESO Wind Integration Study
- 2008: Completed 1st wind integration study for NWE
- 2010 - 2011: Worked on and completed 2nd wind integration study for NWE

GENIVAR's Integration Study Approach

→ Overview of study approach



Scope of NWE Wind Integration Study

- Prove fidelity of dispatch simulator (again)
- Devise wind development scenarios that:
 - Investigate effect of geographical diversity while controlling capacity
 - Investigate effect of added capacity while controlling geographical diversity
- In all scenarios, determine regulating reserves required to meet performance standards
- Investigate merits of alternative operational strategies:
 - Different wind forecasting methods
 - Wind curtailment schemes
 - Intra-hour supply adjustment

Scenario Descriptions

- Study Period: July 1, 2008 to December 31, 2009, inclusive
- 16 Scenarios were run through the dispatch simulator
- 2 trivial scenarios were identified
 - Scenario A: Existing wind - 135 MW Judith Gap & 9 MW Horseshoe Bend \approx 10% load
 - Scenario B: All wind resources removed
- 14 “Development Scenarios” identified by modeling subgroup
 - Based on wind data collected by developers

Scenario Descriptions


→ Pros and Cons of scenario based approach

| Cons | Pros |
|--|--|
| <ul style="list-style-type: none">• Specific in nature• Difficult to generalize | <ul style="list-style-type: none">• Designed to address immediate concerns• As quickly as concerns change, the simulated scenarios can be changed |

Scenario Descriptions

→ Scenario C1: Add 10 MW


- One 10 MW project added near Judith Gap in Wheatland County
- Nameplate Wind Capacity: 154 MW



Scenario Descriptions

→ Scenario C2: Add 10 MW


- One 10 MW project added distant from Judith Gap in Madison County
- Nameplate Wind Capacity: 154 MW



Scenario Descriptions

→ Scenario C3: Add 10 MW


- One 10 MW project added distant from Judith Gap in Glacier County
- Nameplate Wind Capacity: 154 MW



Scenario Descriptions

→ Scenario D1: Add 50 MW


- One 50 MW project added near Judith Gap in Wheatland County
- Nameplate Wind Capacity: 194 MW



Scenario Descriptions

→ Scenario D2: Add 50 MW


- One 50 MW project distant from Judith Gap in Madison County
- Nameplate Wind Capacity: 194 MW



Scenario Descriptions

→ Scenario D3: Add 50 MW


- One 50 MW project distant from Judith Gap in Glacier County
- Nameplate Wind Capacity: 194 MW



Scenario Descriptions

→ Scenario D4: Add 50 MW


- Two 17.5 MW projects and one 15 MW project added
- Nameplate Wind Capacity: 194 MW



Scenario Descriptions

→ Scenario D5: Add 50 MW


- Four 10 MW projects and four 2.5 MW projects added
- Nameplate Wind Capacity: 194 MW



Scenario Descriptions

→ Scenario E1: Add 150 MW


- One 150 MW project added near Judith Gap in Wheatland County
- Nameplate Wind Capacity: 294 MW



Scenario Descriptions

→ Scenario E2: Add 150 MW


- One 150 MW project added distant from Judith Gap in Madison County
- Nameplate Wind Capacity: 294 MW



Scenario Descriptions

→ Scenario E3: Add 150 MW


- One 150 MW project added distant from Judith Gap in Glacier County
- Nameplate Wind Capacity: 294 MW



Scenario Descriptions

→ Scenario E4: Add 150 MW


- One 50 MW project added in each of Madison, Wheatland, and Glacier counties
- Nameplate Wind Capacity: 294 MW



Scenario Descriptions

→ Scenario E5: Add 150 MW


- One 50 MW project, two 25 MW projects, and five 10 MW projects added
- Nameplate Wind Capacity: 294 MW



Scenario Descriptions

→ Scenario F: Add 450 MW, 594 MW Nameplate Wind Capacity

- Two 150 MW projects, one 50 MW project, three 25 MW projects, and two 12.5 MW projects added



Scenario Descriptions

- What information can be extracted from these scenarios?
- Correlation of wind speeds across counties (or lack thereof)
 - Magnitude of wind fluctuations (wrt geographical diversity or wrt added capacity)

Dispatch Simulation Overview


→ Model Inputs

- Simulated Wind Power
- Historical system load, load forecast, and interchange schedule
- Operational parameters (regulating range and rates, supply capacity and rates)

→ Methodology

- Methodology developed by AESO and used for previous NWE Study
- Overall simulation approach maintained but specific algorithms were adapted
- Validate by simulating with historical data and comparing to actual performance
- Establish Benchmark: historical wind data with current regulating reserves
- Determine regulating requirement to maintain a minimum monthly CPS2 Score of 92% and 94% for all wind scenarios


Dispatch Simulation Overview




Dispatch Simulation Overview

→ Control Performance Standard 2 (CPS2)

- Performance rating established by North American Electric Reliability Corporation
- Limits the Area Control Error (ACE) for each balancing authority
- Definition: 90% of the clock-ten-minute averages of ACE for a calendar month must be below a certain threshold, known as L10. NWE L10 is 23.99 MW




Dispatch Simulation Overview



Dispatch Simulation Overview

→ Validation

- Actual historical supply dispatch vs. simulated historical supply dispatch




Mean relative error = -0.23%

Standard deviation of relative error = 3.02%

Dispatch Simulation Overview

→ Validation

- Actual historical CPS2 Scores vs. simulated historical CPS2 Scores vs. benchmark
- Benchmark level of regulating reserve is 96 MW



Dispatch Simulation Overview

→ Sensitivity Case Description

- **Sensitivity 1:** Run Scenario E5 using 30-minute persistence forecasts for wind
 - The wind generation observed 30 minutes in advance of the beginning of the scheduling hour is the scheduled amount
- **Sensitivity 2:** Run Scenario E5 limiting wind generators as follows
 1. For each 10-minute increment (excluding the last ten minutes of each hour), determine if both of the following conditions are present:
 - a. 90% of the available regulating reserves have been deployed
 - b. Aggregate wind generation is over producing versus aggregate schedule
 2. If both conditions 1a and 1b are present, for the next 10-minute increment, cap the output of the wind projects at the higher of:
 - a. The scheduled wind generation amount
 - b. The amount necessary to bring the ACE to 12 MW and maintain a maximum of 90% reserve deployment
- **Sensitivity 3:** Run Scenario E5 using intra-hour supply adjustment as follows
 - At 10 minutes past the hour, calculate system imbalance as:

$$\text{System Imbalance} = \text{Wind Generation} + \text{Other Generation} - \text{Load} - \text{Scheduled Interchange}$$
 - If the magnitude of the system imbalance exceeds 25 MW, increase or decrease the supply by a magnitude equal to the system deficit or surplus, respectively.

Dispatch Simulation Results

→ CPS2 Scores


- Calculated for each of the 16 wind scenarios and 3 sensitivity cases
- Scenarios were compared to characterize effect of wind power w.r.t. geographical diversity and w.r.t added capacity

→ Required Regulating Reserves

- Dispatch simulation model was run iteratively to determine the amount of regulating reserves required to achieve target CPS2 performances
- The targeted performances were 92% and 94%


Dispatch Simulation Results

→ CPS2 comparison example: D5, E5, and F




Dispatch Simulation Results

→ CPS2 comparison example: D4 and D5









Dispatch Simulation Results

→ CPS2 comparison example: E5 and Sensitivity Cases



Dispatch Simulation Results

→ Regulating Reserve Requirements

| Scenario Name | Regulating Reserves Required to Achieve CPS2 Target (MW) | |
|---|--|---------------------------|
| | Minimum CPS2 Score of 94% | Minimum CPS2 Score of 92% |
|   A | 110 | 96 |
|  B | 69 | 59 |
|  C1 | 113.8 | 97.1 |
|  C2 | 108.7 | 92.6 |
|  C3 | 109.2 | 94.6 |
| D1 | 136 | 117 |
| D2 | 112 | 97 |
| D3 | 120 | 101 |
| D4 | 120 | 101 |
| D5 | 105 | 95 |
| E1 | 209 | 181 |
| E2 | 149 | 130 |
| E3 | 163 | 144 |
| E4 | 144 | 126 |
| E5 | 132 | 114 |
| F | 223 | 194 |
| Sensitivity Case 1 - 30 min Wind Forecast | 114 | 98 |
| Sensitivity Case 2 – Wind Curtailment | 114 | 94 |
| Sensitivity Case 3 – Intra-hour Supply Change | 119 | 100 |

Dispatch Simulation Results

→ Descriptive results Sensitivity Case 1:

- Variance of minutely wind forecast errors using 60-minute persistence was 22.5 MW
- Variance of minutely wind forecast errors using 30-minute persistence was 17.7 MW

→ Descriptive results Sensitivity Case 2:

- The amount of curtailed wind energy was 22.5 GWh over the 18 month study period.
- This corresponds to 1.88% of the 1467.1 GWh wind potential.
- Qualitatively, the amount curtailed is sensitive to the accuracy of wind forecast

Lessons Learned

- Benefit of geographical diversity
- *Effect of* incrementing wind capacity is less than the increment
- System performance is sensitive to wind forecasting performance
- System performance benefits from curtailing wind (only in extreme cases)
- System performance benefits from intra-hour supply change (only in extreme cases)

and/or demand response



Other Possibilities

- The possible wind development scenarios are many
- The dispatch simulator is capable of capturing actual dispatch of very different systems: AESO and NWE
- The dispatch simulator is adaptable
 - Can be used to experiment with any dispatch strategy

Questions and Discussion

